



SECTION "A-A"
PMH SWITCHGEAR

NOTES:

1. TEC NO. 2001005 IS A TWO PIECE PRECAST PAD. THE PAD PORTION WEIGHS APPROXIMATELY 2,344 LBS. & THE BOX PORTION WEIGHS APPROXIMATELY 3,140 LBS. IF PRECAST PAD IS NOT AVAILABLE USE POURED IN PLACE PAD PER M-DRAWING *M-5155.
2. FULL RADIUS ELBOWS SHOULD BE USED ON ALL INSTALLATIONS.
3. ON 6" CONDUIT INSTALLATIONS WHERE FULL RADIUS ELBOWS CANNOT BE USED, USE PRECUT ELBOW TEC NO. 5516350.
4. USE 2" CONDUIT(S) FOR REMOTE INDICATION/SUPERVISORY CONTROL IN AUTO GEAR. CONDUIT TO BE IN SWITCH COMPARTMENT BEHIND SOURCE TRANSFER CONTROL CABINET.

◀ DENOTES LATEST REVISION

NO.	CK'D	DATE	REVISION
3			
2	MFK	4-17-03	CONDUIT MOVED OUT OF FUSE BAY INTO SWITCHING BAY
1	MFK	4-17-03	PROPER LOCATION OF THE COMMUNICATION CONDUIT

MGR. STD'S
4-17-03
APPR. DATE
SUPERSEDES 6-18/1-16-97

CONDUIT/PAD DETAILS-600AMP-P.S.E.
MULTI-COMPARTMENT GANG-OPERATED

6-18

TAMPA ELECTRIC CO.

STANDARDS

GENERAL RULES & SPECIFICATIONS UG.