



APPROX.
28,596 LBS.

12 "DIA. X 4"
DEEP SUMP 2"
CLEAR OF WALLS

APPROX.
22,311 LBS.

1" CONDUIT FOR EXTERNAL GROUNDING.
6" CLEAR OF WALLS.
SEE NOTE 10
ON PAGE 2 OF 2

SEE DETAIL "A"
ON PAGE 2 OF 2

SEE NOTE 2
ON PAGE 2 OF 2

SEE DETAIL "B"
ON PAGE 2 OF 2

NOTE:
 1. WITH ADVANCED NOTICE, CONDUIT HOLE PATTERN
 CAN BE ARRANGED TO SUIT ANY APPLICATION AS
 NEEDED FOR THE JOB. SEE YOUR CONDUIT COORDINATOR.
 DETAIL A ON PAGE 2 IS AN EXAMPLE OF THE DEFAULT
 CONDUIT ARRANGEMENT.

◀ DENOTES LATEST REVISION

7'-0" HEAD ROOM
 TEC NO. 5534570

4			
3			
2			
1	JBL	5-21-09	ADDED NEW NOTE 1
NO.	CK'D	DATE	REVISION

MGR: STD'S
 APPR. DATE 5-21-09
 SUPERSEDES 6-2/3-16-95

8' X 12' X 7'
"S" TYPE PRECAST MANHOLE