

The attached list of self-contained meter sockets and enclosures has been approved for use in the service areas served by the utilities of the Meter Equipment Group. Approval is based on the unit's compliance with the MEG specifications, particularly U.L. listing, sealing requirements, bypass characteristics, and certain operational concerns. The MEG makes no claims regarding nameplate ratings or load side attachments beyond the sealed portion of the meter socket. We recommend that all units be used as intended by the manufacturer. All additional data is supplied for informational purposes only.

NOTES:

- A. All commercial or three phase applications require a unit with an approved bypass device. (Configuration 3, 4 or 5)
- B. All sockets are listed as their maximum socket amperage. 320/400 Amp enclosures are listed as 400 Amp maximum and 480/600 Amp enclosures are listed as 600 Amp maximum.
- C. Aluminum enclosures are recommended in salt spray areas.
- D. Sealing rings (ring-type sockets) along with all lugs/connectors (line and load side) are considered to be part of the meter enclosure. The customer/contractor is thereby responsible for furnishing these items. Please contact your utility representative to determine the proper size lugs/connectors. The sealing ring must be a captive-screw type equivalent to ABB #01L0028G02, Milbank MR-4/A3068, Landis & Gyr #9738-8002, or Ekstrom 10-9090.
- E. The "configuration" refers to the various meter connecting arrangements used to accommodate the utility meter. These configurations are described below:

SELF CONTAINED CONFIGURATIONS

DESCRIPTION & TYPICAL APPLICATION

1	Residential - 4 Terminal Socket, Single Phase, 3 Wire
2	Residential - 5 Terminal Socket, Network, 3 Wire
3	Residential/Commercial - 4 Terminal Socket (w/Bypass), Single Phase, 3 Wire
3a	Residential/Commercial - 5 Terminal Socket (w/Bypass), Network, 3 Wire
3b	Residential/Commercial - 5 Terminal socket (w/Bypass), Neutral can be isolated for 3-phase, 3-wire applications.
4	Commercial - 7 Terminal Socket (w/Bypass), Three Phase, 4 Wire
*5	Residential/Commercial – K7 Base (w/Bypass), Single Phase (FPL Only), Three Phase or Network, 3 or 4 Wire

***K7 Three Phase K-Base applications are ONLY allowed at FPL
(GULF, DUKE, OGE and TECO do not allow any K-base installations)**

Participants:





Approved Metering Equipment Enclosure List

Manufacturer	Amps	Catalog Number		Phase	Service	Pos	Term	Bypass	Config
Durham	100	UTZ-6R1131C-FL		1	Ov/Un	6	4	N	1
Durham	100	UTZ-xR1121C-FL	(x=2-5)	1	Ov/Un	2-5	4	N	1
Durham	125	UATZ-RS101C-FL		1	Ov/Un	1	4	N	1 AI
Durham	125	UTZ-RS101C-FL		1	Ov/Un	1	4	N	1
Durham	200	UAT-4300T-FL		3	Over	1	4	Y	1, AI
Durham	200	UAT-H4203x-FL	(x=B or T)	1	Over	1	4	Y	1 AI
Durham	200	UAT-H4213x-FL	(x=C or U)	1	Ov/Un	1	4	Y	1 AI
Durham	200	UAT-H5203x-FL		1	Over	1	5	Y	3,3a,b AI
Durham	200	UAT-H5213x-FL	(x=C or U)	1	Ov/Un	1	5	Y	3,3a,b AI
Durham	200	UAT-H7203x-FL	(x=B or T)	3	Over	1	7	Y	4 AI
Durham	200	UAT-H7213x-FL	(x=C or U)	3	Ov/Un	1	7	Y	4 AI
Durham	200	UAT-RS202B-FL		1	Over	1	4	N	1 AI
Durham	200	UAT-RS212C-FL		1	Ov/Un	1	4	N	1 AI
Durham	200	UAT-RS213A-FL		1	Under	1	4	N	1 AI
Durham	200	UAT-RS213C-FL		1	Ov/Un	1	4	N	1 AI
Durham	200	UAT-RS223A-FL		1	Under	1	4	N	1 AI
Durham	200	UT-4R2352U-FL		1	Ov/Un	4	4	N	1
Durham	200	UT92197CC-FL		1	Ov/Un	1	4	N	1
Durham	200	UT-H4203x-FL	(x=B or T)	1	Over	1	4	Y	1
Durham	200	UT-H4213x-FL	(x=C or U)	1	Ov/Un	1	4	Y	1
Durham	200	UT-H5203x-FL	(x=B or T)	1	Over	1	5	Y	3,3a,b AI
Durham	200	UT-H5213x-FL	(x=C or U)	1	Ov/Un	1	5	Y	3,3a,b AI
Durham	200	UT-H7203x-FL	(x=B or T)	3	Over	1	7	Y	4
Durham	200	UT-RS213A-FL		1	Under	1	4	Y	1
Durham	200	UT-RS213C-FL		1	Ov/Un	1	4	N	1
Durham	200	UT-RS223A-FL		1	Under	1	4	N	1
Durham	200	UT-xR2332U-FL	(x=2-3)	1	Ov/Un	2-3	4	N	1
Durham	200	UT-xR2392UU-FL	(x=5-6)	1	Ov/Un	5-6	4	N	1
Durham	320	UAT-H5330U-FL		1	Ov/Un	1	5	Y	3,3a,b AI
Durham	400	1008836		1	Ov/Un	1	4	Y	1
Durham	400	1008837		1	Ov/Un	1	4	Y	1 AI
Durham	400	UAT-H5300T-FL		1	Over	1	5	Y	3,3a,b AI
Durham	400	UAT-H7300T-FL		3	Over	1	7	Y	4 AI
Durham	400	UAT-H7330U-FL		3	Ov/Un	1	7	Y	4 AI
Durham	400	UT-H4300T-FL		1	Over	1	4	Y	1



Approved Metering Equipment Enclosure List

Manufacturer	Amps Catalog Number	Phase	Service	Pos	Term	Bypass	Config
Durham	400 UT-H5300T-FL	1	Over	1	5	Y	3,3a,b
Durham	400 UT-H5330U-FL	1	Ov/Un	1	5	Y	3,3a,b
Durham	400 UT-H7300T-FL	3	Over	1	7	Y	4
Durham	400 UT-H7330U-FL	3	Ov/Un	1	7	Y	4
Eaton B-Line	100 ECCB10L25A3xx1F (xx=GR, AL, S4, S6)	1	OH/UG	1	5	Y	3a
Eaton B-Line	100 ECCB10L27A3xx1F (xx=GR, AL, S4, S6)	3	OH/UG	1	7	Y	4
Eaton B-Line	100 ENCB10L25A3xx1F (xx=GR, AL, S4, S6)	1	OH/UG	1	5	N	1,2
Eaton B-Line	100 HEC10432Cxx1F (xx=GR, AL, S4, S6)	1	OH/UG	2	4	Y	3
Eaton B-Line	100 HEC10433Cxx1F (xx=GR, AL, S4, S6)	1	OH/UG	3	4	Y	3
Eaton B-Line	100 HEN10432Lxx1F (xx=GR, AL, S4, S6)	1	OH/UG	2	4	N	3
Eaton B-Line	100 HEN10433Lxx1F (xx=GR, AL, S4, S6)	1	OH/UG	3	4	N	3
Eaton B-Line	100 HEN10434Lxx1F (xx=GR, AL, S4, S6)	1	OH/UG	4	4	N	3
Eaton B-Line	100 HEN10435Lxx1F (xx=GR, AL, S4, S6)	1	OH/UG	5	4	N	3
Eaton B-Line	100 HEN10436Lxx1F (xx=GR, AL, S4, S6)	1	OH/UG	6	4	N	3
Eaton B-Line	125 EC12L53xx1F (xx=GR, AL, S4, S6)	1	OH/UG	1	5	Y	3,3a,b
Eaton B-Line	125 EN12L41xx1F (xx=GR, AL, S4, S6)	1	OH	1	4	N	1
Eaton B-Line	125 EN12L42xx1F (xx=GR, AL, S4, S6)	1	UG	1	4	N	1
Eaton B-Line	125 EN12L43xx1F (xx=GR, AL, S4, S6)	1	OH/UG	1	4	N	1
Eaton B-Line	125 EN12L51xx1F (xx=GR, AL, S4, S6)	1	OH	1	5	N	1,2
Eaton B-Line	125 EN12L52xx1F (xx=GR, AL, S4, S6)	1	UG	1	5	N	1,2
Eaton B-Line	125 EN12L53xx1F (xx=GR, AL, S4, S6)	1	OH/UG	1	5	N	1,2
Eaton B-Line	125 VENMP12432Lxx1F (xx=GR, AL, S4, S6)	1	OH/UG	2	4	N	3
Eaton B-Line	125 VENMP12433Lxx1F (xx=GR, AL, S4, S6)	1	OH/UG	3	4	N	3
Eaton B-Line	125 VENMP12434Cxx1F (xx=GR, AL, S4, S6)	1	OH/UG	4	4	N	3
Eaton B-Line	125 VENMP12435Cxx1F (xx=GR, AL, S4, S6)	1	OH/UG	5	4	N	3
Eaton B-Line	125 VENMP12436Cxx1F (xx=GR, AL, S4, S6)	1	OH/UG	6	4	N	3
Eaton B-Line	150 ENCB15L25A3xx1F (xx=GR, AL, S4, S6)	1	OH/UG	1	5	N	1,2
Eaton B-Line	200 EL20L53xx1F (xx=GR, AL, S4, S6)	1	OH/UG	1	5	Y	3,3a,b
Eaton B-Line	200 EL20L73xx1F (xx=GR, AL, S4, S6)	3	OH/UG	1	7	Y	4
Eaton B-Line	200 ELCB20L25A3xx1F (xx=GR, AL, S4, S6)	1	OH/UG	1	5	Y	3,3a
Eaton B-Line	200 ELCB20L27A3xx1F (xx=GR, AL, S4, S6)	3	OH/UG	1	7	Y	4
Eaton B-Line	200 EN20L41xx1F (xx=GR, AL, S4, S6)	1	OH	1	4	N	1
Eaton B-Line	200 EN20L42xx1F (xx=GR, AL, S4, S6)	1	UG	1	4	N	1
Eaton B-Line	200 EN20L43xx1F (xx=GR, AL, S4, S6)	1	OH/UG	1	4	N	1
Eaton B-Line	200 EN20L51xx1F (xx=GR, AL, S4, S6)	1	OH	1	5	N	1,2
Eaton B-Line	200 EN20L52xx1F (xx=GR, AL, S4, S6)	1	UG	1	5	N	1,2



Approved Metering Equipment Enclosure List

Manufacturer	Amps Catalog Number	Phase Service	Pos	Term	Bypass	Config
Eaton B-Line	200 EN20L53xx1F (xx=GR, AL, S4, S6)	1 OH/UG	1	5	N	1,2
Eaton B-Line	200 ENCB20L25A3xx1F (xx=GR, AL, S4, S6)	1 OH/UG	1	5	N	1,2
Eaton B-Line	200 HEL20432Cxx1F (xx=GR, AL, S4, S6)	1 OH/UG	2	4	Y	3
Eaton B-Line	200 HEL20433Cxx1F (xx=GR, AL, S4, S6)	1 OH/UG	3	4	Y	3
Eaton B-Line	200 HEL20434Cxx1F (xx=GR, AL, S4, S6)	1 OH/UG	4	4	Y	3
Eaton B-Line	200 HEL20435Cxx1F (xx=GR, AL, S4, S6)	1 OH/UG	5	4	Y	3
Eaton B-Line	200 HEL20436Cxx1F (xx=GR, AL, S4, S6)	1 OH/UG	6	4	Y	3
Eaton B-Line	200 HEL20732Cxx1F (xx=GR, AL, S4, S6)	3 OH/UG	2	7	Y	4
Eaton B-Line	200 HEL20733Cxx1F (xx=GR, AL, S4, S6)	3 OH/UG	3	7	Y	4
Eaton B-Line	200 HEL20734Cxx1F (xx=GR, AL, S4, S6)	3 OH/UG	4	7	Y	4
Eaton B-Line	200 HEL20735Cxx1F (xx=GR, AL, S4, S6)	3 OH/UG	5	7	Y	4
Eaton B-Line	200 HEL20736Cxx1F (xx=GR, AL, S4, S6)	3 OH/UG	6	7	Y	4
Eaton B-Line	200 VENMP20432Lxx1F (xx=GR, AL, S4, S6)	1 OH/UG	2	4	N	3
Eaton B-Line	200 VENMP20433Lxx1F (xx=GR, AL, S4, S6)	1 OH/UG	3	4	N	3
Eaton B-Line	200 VENMP20434Cxx1F (xx=GR, AL, S4, S6)	1 OH/UG	4	4	N	3
Eaton B-Line	200 VENMP20435Cxx1F (xx=GR, AL, S4, S6)	1 OH/UG	5	4	N	3
Eaton B-Line	200 VENMP20436Cxx1F (xx=GR, AL, S4, S6)	1 OH/UG	6	4	N	3
Eaton B-Line	400 EL32T53xx1F (xx=GR, AL, S4, S6)	1 OH/UG	1	5	Y	3,3a
Eaton B-Line	400 EL32T56xx1F (xx=GR, AL, S4, S6)	1 OH/UG	1	5	Y	3,3a
Eaton B-Line	400 EL32T75xx1F (xx=GR, AL, S4, S6)	3 OH/UG	1	7	Y	4
Eaton B-Line	400 EL32T76xx1F (xx=GR, AL, S4, S6)	3 OH/UG	1	7	Y	4
Eaton B-Line	400 ELCB32C25A5xx1F (xx=GR, AL, S4, S6)	1 OH/UG	1	5	Y	3,3a
Eaton-Cutler Hammer	100 MB1224B100BTS	1 Ov/Un	1	4	N	1
Eaton-Cutler Hammer	100 UATZ-xR1121CFLCH (x=2-5)	1 Ov/Un	2-5	4	N	1 Al
Eaton-Cutler Hammer	100 UATZxR1121CFLCH (x = 2 - 5)	1 Ov/Un	2-5	4	N	1 AL
Eaton-Cutler Hammer	125 1MMx12RP, RCP, RRLP or RRLCP (x=3-6)	1 Ov/Un	3-6	4	N	1
Eaton-Cutler Hammer	125 1MPx124RP, RRLP or RRLCP (x=3-4)	1 Ov/Un	3-4	4	N	1
Eaton-Cutler Hammer	125 1MPx126RP, RRLP or RRLCP (x=5-6)	1 Ov/Un	5-6	4	N	1
Eaton-Cutler Hammer	125 3MMx12R12P (x=2-6)	1 Ov/Un	2-6	4	N	1
Eaton-Cutler Hammer	125 3MMx12R12RLP (x=2-6)	1 Ov/Un	2-6	4	N	1
Eaton-Cutler Hammer	125 3MMx12RCP (x=2-6)	1 Ov/Un	2-6	4	N	1
Eaton-Cutler Hammer	125 3MMx12RP (x=2-6)	1 Ov/Un	2-6	4	N	1
Eaton-Cutler Hammer	125 3MMx12RRRLCP (x=2-6)	1 Ov/Un	2-6	4	N	1
Eaton-Cutler Hammer	125 3MMx12RRRLP (x=2-6)	1 Ov/Un	2-6	4	N	1
Eaton-Cutler Hammer	125 CHR (POWER OUTLET PANEL)	1 Ov/Un	1	4	N	1
Eaton-Cutler Hammer	125 MBT48B125BTS	1 Ov/Un	1	4	N	1



Approved Metering Equipment Enclosure List

Manufacturer	Amps	Catalog Number		Phase	Service	Pos	Term	Bypass	Config
Eaton-Cutler Hammer	125	UATZ-RS101C-FLCH		1	Ov/Un	1	4	N	1 AI
Eaton-Cutler Hammer	125	UT-RS101xE (x=B,C)		1	Ov/Un	1	4	N	1
Eaton-Cutler Hammer	125	UTZ-RS101C-FLCH		1	Ov/Un	1	4	N	1
Eaton-Cutler Hammer	150	MB816B150BTS		1	Ov/Un	1	4	N	1
Eaton-Cutler Hammer	150	MBB150BTS		1	Ov/Un	1	4	N	1
Eaton-Cutler Hammer	150	MBT48B150BTS		1	Ov/Un	1	4	N	1
Eaton-Cutler Hammer	200	1MMx20RRLP or RRLCP	(x=3-4)	1	Ov/Un	3-4	4	N	3
Eaton-Cutler Hammer	200	1MP2204RP, RRLP or RRLCP		1	Ov/Un	2	4	N	1
Eaton-Cutler Hammer	200	1MPx206RP, RRLP or RRLCP	(x=3-6)	1	Ov/Un	3-6	4	N	1
Eaton-Cutler Hammer	200	3MMx20R12P (x=2-5)		1	Ov/Un	2-5	4	N	3
Eaton-Cutler Hammer	200	3MMx20R12RPL (x=2-5)		1	Ov/Un	2-5	4	N	3
Eaton-Cutler Hammer	200	3MMx20RCP (x=2-5)		1	Ov/Un	2-5	4	N	3
Eaton-Cutler Hammer	200	3MMx20RP (x=2-5)		1	Ov/Un	2-5	4	N	3
Eaton-Cutler Hammer	200	3MMx20RRLCP (x=2-5)		1	Ov/Un	2-5	4	N	3
Eaton-Cutler Hammer	200	3MMx20RRLP (x=2-5)		1	Ov/Un	2-5	4	N	3
Eaton-Cutler Hammer	200	CMB1212B200BTS		1	Ov/Un	1	4	N	1
Eaton-Cutler Hammer	200	CMB1212L200BTS		1	Ov/Un	1	4	N	1
Eaton-Cutler Hammer	200	CMB1212P200BTS		1	Ov/Un	1	4	N	1
Eaton-Cutler Hammer	200	CMB2424B200BTS		1	Ov/Un	1	4	N	1
Eaton-Cutler Hammer	200	CMB2436B200BTS		1	Ov/Un	1	4	N	1
Eaton-Cutler Hammer	200	MB1212L200BTS		1	Ov/Un	1	4	N	1
Eaton-Cutler Hammer	200	MB1212L200BTSA		1	Ov/Ln	1	4	N	1 AI
Eaton-Cutler Hammer	200	MB2040B200BTS		1	Ov/Un	1	4	N	1
Eaton-Cutler Hammer	200	MB2040P200BTS		1	Ov/Un	1	4	N	1
Eaton-Cutler Hammer	200	MB4040B200BTS		1	Ov/Un	1	4	N	1
Eaton-Cutler Hammer	200	MB816B200BTS		1	Ov/Un	1	4	N	1
Eaton-Cutler Hammer	200	MB816P200BTS or BTSCU		1	Ov/Un	1	4	N	1
Eaton-Cutler Hammer	200	MBB200BTS		1	Ov/Un	1	4	N	1
Eaton-Cutler Hammer	200	MBP200BTS		1	Ov/Un	1	4	N	1
Eaton-Cutler Hammer	200	MBT48B200BTS		1	Ov/Un	1	4	N	1
Eaton-Cutler Hammer	200	UAT-4R2352UFLCH		1	Ov/Un	4	4	N	1 AL
Eaton-Cutler Hammer	200	UAT-H4203x-FLCH	(x=B or T)	1	Over	1	4	Y	1 AI
Eaton-Cutler Hammer	200	UAT-H5203x-FLCH	(x=B or T)	1	Over	1	5	Y	3,3a,b AI
Eaton-Cutler Hammer	200	UAT-H7203x-FLCH	(x=B or T)	3	Over	1	7	Y	4 AI
Eaton-Cutler Hammer	200	UAT-RS202B-FLCH		1	Over	1	4	N	1 AI
Eaton-Cutler Hammer	200	UAT-RS212C-FLCH		1	Ov/Un	1	4	N	1 AI



Approved Metering Equipment Enclosure List

Manufacturer	Amps	Catalog Number	Phase	Service	Pos	Term	Bypass	Config
Eaton-Cutler Hammer	200	UAT-RS213A-FLCH	1	Under	1	4	N	1 AI
Eaton-Cutler Hammer	200	UAT-RS213C-FLCH	1	Ov/Un	1	4	N	1 AI
Eaton-Cutler Hammer	200	UAT-RS223A-FLCH	1	Under	1	4	N	1 AI
Eaton-Cutler Hammer	200	UAT-xR2332U-FLCH (x=2-3)	1	Ov/Un	2-3	4	N	1
Eaton-Cutler Hammer	200	UATxR2392UUFLCH (x=5-6)	1	Ov/Un	5-6	4	N	1 AI
Eaton-Cutler Hammer	200	UAT-y4213x-FLCH (y=E or H, where x=C or U)	1	Ov/Un	1	4	Y	1 AI
Eaton-Cutler Hammer	200	UAT-y5213x-FLCH (y=E or H, where x=C or U)	1	Ov/Un	1	5	Y	3,3a,b AI
Eaton-Cutler Hammer	200	UAT-y7213x-FLCH (y=E or H, where x=C or U)	3	Ov/Un	1	7	Y	4 AI
Eaton-Cutler Hammer	200	UT-4R2352U-FLCH	1	Ov/Un	4	4	N	1
Eaton-Cutler Hammer	200	UT92197CC-FL-CH	1	Ov/Un	1	4	N	1
Eaton-Cutler Hammer	200	UT-RS202B-FLCH	1	Over	1	4	N	1
Eaton-Cutler Hammer	200	UT-RS212C-FLCH	1	Ov/Un	1	4	N	1
Eaton-Cutler Hammer	200	UT-RS213A-FLCH	1	Under	1	4	N	1
Eaton-Cutler Hammer	200	UT-RS213CE	1	Ov/Un	1	4	N	1
Eaton-Cutler Hammer	200	UT-RS213C-FLCH	1	Ov/Un	1	4/5	N	1, 2
Eaton-Cutler Hammer	200	UT-RS223A-FLCH	1	Under	1	4	N	1
Eaton-Cutler Hammer	200	UT-xR2332U-FLCH (x=2-3)	1	Ov/Un	2-3	4	N	1
Eaton-Cutler Hammer	200	UT-xR2392UU-FLCH (x=5-6)	1	Ov/Un	5-6	4	N	1
Eaton-Cutler Hammer	200	UT-y4203x-FLCH (y=E or H, where x=B or T)	1	Over	1	4	Y	1
Eaton-Cutler Hammer	200	UT-y4213x-FLCH (y=E or H, where x=C or U)	1	Ov/Un	1	4	Y	1
Eaton-Cutler Hammer	200	UT-y5203x-FLCH (y=E or H, where x=B or T)	1	Over	1	5	Y	3,3a,b
Eaton-Cutler Hammer	200	UT-y5213x-FLCH (y=E or H, where x=C or U)	1	Ov/Un	1	5	Y	3,3a,b
Eaton-Cutler Hammer	200	UT-y7203x-FLCH (y=E or H, where x=B or T)	3	Over	1	7	Y	4
Eaton-Cutler Hammer	200	UT-y7213x-FLCH (where y=E or H, x=C or U)	3	Ov/Un	1	7	Y	4
Eaton-Cutler Hammer	225	35MMx20R12 or R12C (x=1-4)	1	Ov/Un	1-4	5	Y	3,3a
Eaton-Cutler Hammer	225	37MMx20R12 or R12C (x=1-4)	3	Ov/Un	1-4	7	Y	4
Eaton-Cutler Hammer	400	1008836CH	1	Ov/Un	1	4	Y	1
Eaton-Cutler Hammer	400	1008837CH	1	Ov/Un	1	4	Y	1 AI
Eaton-Cutler Hammer	400	1011619CH	1	Ov/Un	1	4	Y	1
Eaton-Cutler Hammer	400	35MM140R1240	1	Under	1	5	Y	3
Eaton-Cutler Hammer	400	35MM240R1240	1	Under	2	5	Y	3
Eaton-Cutler Hammer	400	37MM140R1240	3	Under	1	7	Y	4
Eaton-Cutler Hammer	400	37MM240R1240	3	Under	1	7	Y	4
Eaton-Cutler Hammer	400	CG1212P400BSL	1	Under	1	4	Y	3
Eaton-Cutler Hammer	400	CG404242SHL	1	Under	1	4	Y	3
Eaton-Cutler Hammer	400	CG40SHL	1	Under	1	4	Y	3



Approved Metering Equipment Enclosure List

Manufacturer	Amps Catalog Number	Phase	Service	Pos	Term	Bypass	Config
Eaton-Cutler Hammer	400 HP404040SHL	1	Under	1	4	Y	3
Eaton-Cutler Hammer	400 HP40SHL	1	Under	1	4	Y	3
Eaton-Cutler Hammer	400 HP816Px00BSL (x = 3 or 4)	1	Under	1	4	Y	3
Eaton-Cutler Hammer	400 HPCx046SHLG (x= 3 or 4)	1	Ov/Un	1	4	y	3
Eaton-Cutler Hammer	400 HPCx0SHL (x= 3 or 4)	1	Ov/Un	1	4	y	3
Eaton-Cutler Hammer	400 UAT-H4300T-FLCH	1	Over	1	4	Y	1 AI
Eaton-Cutler Hammer	400 UAT-H5300T-FLCH	1	Over	1	5	Y	3,3a,b AI
Eaton-Cutler Hammer	400 UAT-H5330U-FLCH	1	Ov/Un	1	5	Y	3,3a,b AI
Eaton-Cutler Hammer	400 UAT-H7300T-FLCH	3	Over	1	7	Y	4 AI
Eaton-Cutler Hammer	400 UAT-H7330U-FLCH	3	Ov/Un	1	7	Y	4 AI
Eaton-Cutler Hammer	400 UT-H4300T-FLCH	1	Over	1	4	Y	1
Eaton-Cutler Hammer	400 UTH43068TFLCH	1	Ov/Un	1	4	Y	1
Eaton-Cutler Hammer	400 UT-H5300T-FLCH	1	Over	1	5	Y	3,3a,b
Eaton-Cutler Hammer	400 UT-H5330U-FLCH	1	Ov/Un	1	5	Y	3,3a,b
Eaton-Cutler Hammer	400 UT-H7300T-FLCH	3	Over	1	7	Y	4
Eaton-Cutler Hammer	400 UT-H7330U-FLCH	3	Ov/Un	1	7	Y	4
Eaton-Cutler Hammer	400 UTH73368UFLCH	3	Ov/Un	1	7	Y	4
Eaton-Cutler Hammer	600 CH9526K7 (Requires Ridged Lugs) FPL ONLY	3	Ov/Un	1	7	Y	5
Eaton-Cutler Hammer	600 CH9527K7 (Requires Ridged Lugs) FPL ONLY	3	Ov/Un	1	7	Y	5 AI
Elec.Prod.	100 RVP-xxxx-FPL	1	Under	1	4	N	1
Elec.Prod.	200 MHP-xxxx-FPL	1	Under	1	4	N	1
Emerson	125 MESBGFXLW11FBZ1	1	Under	1	5	Y	3a
Emerson	125 MESBGFXLW11FBZ1P	1	Under	1	5	Y	3a
Emerson	125 MESBGFXLW11KBZ1	1	Under	1	5	Y	3a
Emerson	125 MESBGFXLW11KBZ1P	1	Under	1	5	Y	3a
Emerson	200 MESBAATLW11FBZ1	1	Under	1	5	Y	3a
Emerson	200 MESBAATLW11FBZ1P	1	Under	1	5	Y	3a
Emerson	200 MESBAATLW11KBZ1	1	Under	1	5	Y	3a
Emerson	200 MESBAATLW11KBZ1P	1	Under	1	5	Y	3a
General Electric	(2) 150TSDR830USCU	1	Under	1	4/5	Y	1,2
General Electric	100 TM10RMCFMG	1	Ov/Un	1	4	N	1
General Electric	100 UTZ-6R1131CFLGE	1	Ov/Un	6	4	N	1
General Electric	100 UTZ-xR1121CFLGE (x=2-5)	1	Ov/Un	6	4/5	N	1,2
General Electric	125 TM12RMCFMG	1	Ov/Un	1	4	N	1
General Electric	125 TMM2212RF	1	Ov/Un	2	4	N	1
General Electric	125 TMM4x12RF (x=3-4)	1	Under	3-4	4	N	1



Approved Metering Equipment Enclosure List

Manufacturer	Amps	Catalog Number	Phase	Service	Pos	Term	Bypass	Config
General Electric	125	TMM6x12RF (x=5-6)	1	Under	5-6	4	N	1
General Electric	125	TMMR2212RF	1	Ov/Un	2	4/5	N	1,2
General Electric	125	TMMR4x12RF (x=3-4)	1	Under	3-4	4/5	N	1,2
General Electric	125	TMMR6x12RF (x=5-6)	1	Under	5-6	4/5	N	1,2
General Electric	125	TMPR12x12RF (x=2-6)	1	Ov/Un	2-6	5	N	2
General Electric	125	TMPR8x12RF (x=2-6)	1	Ov/Un	2-6	4	N	1,2
General Electric	125	UATZ-RS101CFLGE	1	Ov/Un	1	4	N	1 AI
General Electric	125	UTZ-RS101C-FLGE	1	Ov/Un	1	4	N	1
General Electric	150	TM15RMCFMG	1	Ov/Un	1	4	N	1
General Electric	150	TSMR415CSFLFMG	1	Ov/Un	1	5	N	2
General Electric	150	TSMR815CSFLFMG	1	Ov/Un	1	5	N	2
General Electric	200	TM20RMCFMG	1	Ov/Un	1	4	N	1
General Electric	200	TMM6x20RF (x=3-4)	1	Under	3-4	4	N	1
General Electric	200	TMMR4220RF	1	Under	2	5	N	2
General Electric	200	TMMR6x20RF (x=3-6)	1	Under	3-6	5	N	2
General Electric	200	TMPR12x20RF (x=4-5)	1	Ov/Un	4-5	5	N	2
General Electric	200	TMPR8x20RF (x=2-5)	1	Ov/Un	2-5	5	N	2
General Electric	200	TSLR1220FSAL	1	Ov/Un	1	4/5	N	1, 2
General Electric	200	TSMR2020CSCUFMG	1	Ov/Un	1	4/5	N	1,2
General Electric	200	TSMRx20CSFLFMG (x = 4, 8)	1	Ov/Un	1	4/5	N	1,2
General Electric	200	UAT-H4203x-FLGE (x=B or T)	1	Over	1	4	Y	1 AI
General Electric	200	UAT-H4213x-FLGE (x=C or U)	1	Ov/Un	1	4	Y	1 AI
General Electric	200	UAT-H5203x-FLGE (x=B or T)	1	Over	1	5	Y	3,3a,b AI
General Electric	200	UAT-H5213x-FLGE (x=C or U)	1	Ov/Un	1	5	Y	3,3a,b AI
General Electric	200	UAT-H7203x-FLGE (x=B or T)	3	Over	1	7	Y	4 AI
General Electric	200	UAT-H7213x-FLGE (x=C or U)	1	Ov/Un	1	7	Y	4 AI
General Electric	200	UAT-RS202B-FLGE	1	Over	1	4	N	1 AI
General Electric	200	UAT-RS212C-FLGE	1	Ov/Un	1	4	N	1 AI
General Electric	200	UAT-RS213A-FLGE	1	Under	1	4	N	1 AI
General Electric	200	UAT-RS213C-FLGE	1	Ov/Un	1	4	N	1 AI
General Electric	200	UAT-RS223A-FLGE	1	Under	1	4	N	1 AI
General Electric	200	UT-4R2352U-FLGE	1	Ov/Un	1	4	N	1
General Electric	200	UT92197CC-FL-GE	1	Ov/Un	1	4	N	1
General Electric	200	UT-H4203x-FL-GE (x=B or T)	1	Over	1	4	Y	1
General Electric	200	UT-H4213x-FL-GE (x=C or U)	1	Ov/Un	1	4	Y	1
General Electric	200	UT-H5203x-FL-GE (x=B or T)	1	Over	1	5	Y	3,3a,b



Approved Metering Equipment Enclosure List

Manufacturer	Amps	Catalog Number		Phase	Service	Pos	Term	Bypass	Config
General Electric	200	UT-H5213x-FL-GE	(x=C or U)	1	Ov/Un	1	5	Y	3,3a,b
General Electric	200	UT-H7203x-FL-GE	(x=B or T)	1	Over	1	7	Y	4
General Electric	200	UT-RS213A-FL-GE		1	Under	1	4	N	1
General Electric	200	UT-RS213C-FL-GE		1	Ov/Un	1	4	N	1
General Electric	200	UT-RS223A-FL-GE		1	Under	1	4	N	1
General Electric	200	UT-xR2332U-FLGE	(x=2-3)	1	Ov/Un	1	4	N	1
General Electric	200	UT-xR2392UUFLGE	(x=5-6)	1	Ov/Un	1	4	N	1
General Electric	225	TMPR12x22R	(x=1-4)	1	Ov/Un	1-4	5	Y	3,3a
General Electric	225	TMPR312x22RF	(x=1-4)	3	Ov/Un	1-4	7	Y	4
General Electric	400	1008836-GE		1	Ov/Un	1	4	Y	1
General Electric	400	1008837-GE		1	Ov/Un	1	4	Y	1 AI
General Electric	400	TMPR12x40RB	(x=1-2)	1	Ov/Un	1-2	5	N	3,3a
General Electric	400	TMPR312x40RB	(x=1-2)	3	Ov/Un	1-2	7	Y	4
General Electric	400	TSDR840UFCU		1	Under	1	4/5	Y	1,2
General Electric	400	UAT-H4300T-FLGE		1	Over	1	4	Y	1 AI
General Electric	400	UAT-H5300T-FLGE		1	Over	1	5	Y	3,3a,b AI
General Electric	400	UAT-H5330U-FLGE		1	Ov/Un	1	5	Y	3,3a AI
General Electric	400	UAT-H7300T-FLGE		3	Over	1	7	Y	4 AI
General Electric	400	UAT-H7330U-FLGE		3	Ov/Un	1	7	Y	4 AI
General Electric	400	UT-H4300T-FL-GE		1	Over	1	4	Y	1
General Electric	400	UT-H5300T-FL-GE		1	Over	1	5	Y	3,3a,b
General Electric	400	UT-H5330U-FL-GE		1	Ov/Un	1	5	Y	3,3a,b
General Electric	400	UT-H7300T-FL-GE		3	Over	1	7	Y	4
General Electric	400	UT-H7330U-FL-GE		3	Ov/Un	1	7	Y	4
Midwest	100	R075CB6010FMG		1	Un-Ped	1	4	N	1
Midwest	100	R075CP6010FMG		1	Un-Ped	1	4	N	1
Midwest	100	R102EN		1	Over	1	4	N	1
Midwest	100	UTZ6R1131CFLMEP		1	Ov/Un	6	4	N	1
Midwest	100	UTZxR1121CFLMEP	(x=2-5)	1	Ov/Un	2-5	4	N	1
Midwest	125	UATZRS101CFLMEP		1	Ov/Un	1	4	N	1 AI
Midwest	125	UTZ-RS101CFLMEP		1	Ov/Un	1	4	N	1
Midwest	150	R158CR2TLFMG		1	Ov/Un	1	4	N	1
Midwest	150	RS43308C	(2x 150MB)	1	Ov/Un	1	4	Y	3
Midwest	200	R208CR2TLFMG		1	Ov/Un	1	4	N	1
Midwest	200	R256EB118FMG		1	Ov/Un	1	4	N	1, AI
Midwest	200	R256EB1FMG		1	Ov/Un	1	4	N	1



Approved Metering Equipment Enclosure List

Manufacturer	Amps	Catalog Number		Phase	Service	Pos	Term	Bypass	Config
Midwest	200	R256EB1NFMG		1	Ov/Un	1	4	N	1
Midwest	200	RS45500C (2 X 200MB)		1	Under	1	4	Y	3
Midwest	200	RS45508C (2 X 200MB)		1	Under	1	4	Y	3
Midwest	200	UAT-H4203xFLMEP	(x=B or T)	1	Over	1	4	Y	1 AI
Midwest	200	UAT-H4213xFLMEP	(x=C or U)	1	Ov/Un	1	4	Y	1 AI
Midwest	200	UAT-H5203xFLMEP	(x=B or T)	1	Over	1	5	Y	3,3a,b AI
Midwest	200	UAT-H5213xFLMEP	(x=C or U)	1	Ov/Un	1	5	Y	3,3a,b AI
Midwest	200	UAT-H7203x-FLMEP	(x=B or T)	3	Over	1	7	Y	4 AI
Midwest	200	UAT-H7213xFLMEP	(x=C or U)	3	Ov/Un	1	7	Y	4 AI
Midwest	200	UAT-RS202BFLMEP		1	Over	1	4	N	1 AI
Midwest	200	UAT-RS212CFLMEP		1	Ov/Un	1	4	N	1 AI
Midwest	200	UAT-RS213AFLMEP		1	Under	1	4	N	1 AI
Midwest	200	UAT-RS213CFLMEP		1	Ov/Un	1	4	N	1 AI
Midwest	200	UAT-RS223AFLMEP		1	Under	1	4	N	1 AI
Midwest	200	UT-4R2352UFLMEP		1	Ov/Un	4	4	N	1
Midwest	200	UT92197CC-FLMEP		1	Ov/Un	1	4	N	1
Midwest	200	UT-H4203x-FLMEP	(x=B or T)	1	Over	1	4	Y	1
Midwest	200	UT-H4213x-FLMEP	(x=C or U)	1	Ov/Un	1	4	Y	1
Midwest	200	UT-H5203x-FLMEP	(x=B or T)	1	Over	1	5	Y	3,3a,b
Midwest	200	UT-H5213x-FLMEP	(x=C or U)	1	Ov/Un	1	5	Y	3,3a,b
Midwest	200	UT-H7203x-FLMEP	(x=B or T)	3	Over	1	7	Y	4
Midwest	200	UT-RS213A-FLMEP		1	Under	1	4	N	1
Midwest	200	UT-RS213C-FLMEP		1	Ov/Un	1	4	N	1
Midwest	200	UT-RS223A-FLMEP		1	Under	1	4	N	
Midwest	200	UT-xR2332UFLMEP	(x=2-3)	1	Ov/Un	2-3	4	N	1
Midwest	200	UTxR2392UUFLMEP	(x = 5-6)	1	Ov/Un	5-6	4	N	1
Midwest	400	1008836-MEP		1	Ov/Un	1	4	Y	1
Midwest	400	1008837-MEP		1	Ov/Un	1	4	Y	1 AI
Midwest	400	RS45524CFMG		1	Under	1	4/5	Y	1,2
Midwest	400	UAT-H4300TFLMEP		1	Over	1	4	Y	1 AI
Midwest	400	UAT-H5300TFLMEP		1	Over	1	5	Y	3,3a,b AI
Midwest	400	UAT-H5330UFLMEP		1	Ov/Un	1	5	Y	3,3a,b AI
Midwest	400	UAT-H7300TFLMEP		3	Over	1	7	Y	4 AI
Midwest	400	UAT-H7330UFLMEP		3	Ov/Un	1	7	Y	4 AI
Midwest	400	UT-H4300T-FLMEP		1	Over	1	4	Y	1
Midwest	400	UT-H5300T-FLMEP		1	Over	1	5	Y	3,3a,b



Approved Metering Equipment Enclosure List

Manufacturer	Amps	Catalog Number		Phase	Service	Pos	Term	Bypass	Config
Midwest	400	UT-H5330UFLMEP		1	Ov/Un	1	5	Y	3,3a,b
Midwest	400	UT-H7300TFLMEP		3	Over	1	7	Y	4
Midwest	400	UT-H7330UFLMEP		3	Ov/Un	1	7	Y	4
Milbank	100	U349y-XL-HSP	(y=2-6)	1	Ov/Un	2-6	4/5	N	1,2
Milbank	100	U513y-O-100P-FMG	(y=6-9)	1	Un-Ped	1-2	4/5	N	1,2
Milbank	100	U513y-O-100S-10GR-FMG	(y=6-9)	1	Un-Ped	1-2	4/5	N	1,2
Milbank	100	U513y-O-100S-FMG	(y=6-9)	1	Un-Ped	1-2	4/5	N	1,2
Milbank	100	U5842-RL-100-HSP		1	Over	1	4	N	1
Milbank	100	U6266-XTL-100-HSP		1	Ov/Un	1	4/5	N	1,2
Milbank	100	UAP349y-XL-HSP	(y=2-6)	1	Ov/Un	2-6	4/5	N	1,2 AI
Milbank	125	U285y-X-HSP	(y=2-6)	1	Ov/Un	2-6	4/5	N	1,2
Milbank	125	U3505-XL-HSP		1	Ov/Un	1	5	Y	3,3a
Milbank	125	U3505-XL-TG-HSP		1	Ov/Un	1	5	Y	3,3a
Milbank	125	U3506-XL-TG-HSP		3	Ov/Un	1	7	Y	4
Milbank	125	U513y-O-125P-FMG	(y=6-9)	1	Un-Ped	1-2	4/5	N	1,2
Milbank	125	U513y-O-125S-FMG	(y=6-9)	1	Un-Ped	1-2	4/5	N	1,2
Milbank	125	U8435-XL-TG-HSP		1	Ov/Un	1	4/5	N	1,2
Milbank	125	UAP3505-XL-TG-HSP		1	Ov/Un	1	5	Y	3,3a AI
Milbank	125	UAP3506-XL-TG-HSP		3	Ov/Un	1	7	Y	4 AI
Milbank	125	UAP8435-XL-TG-HSP		1	Ov/Un	1	4/5	N	1,2 AI
Milbank	150	U123y-X-HSP	(y=2-6)	1	Ov/Un	2-6	4/5	N	1,2
Milbank	150	U3312-XL-TG-HSP		1	Ov/Un	1	4/5	N	1,2
Milbank	150	U513y-O-150P-FMG	(y=6-9)	1	Un-Ped	1-2	4/5	N	1,2
Milbank	150	U513y-O-150S-10GR-FMG	(y=6-9)	1	Un-Ped	1-2	4/5	N	1,2
Milbank	150	U513y-O-150S-FMG	(y=6-9)	1	Un-Ped	1-2	4/5	N	1,2
Milbank	150	U5842-RL-150-HSP		1	Over	1	4	N	1
Milbank	150	U6266-XTL-150-HSP		1	Ov/Un	1	4/5	N	1,2
Milbank	150	UAP123y-X-HSP	(y=2-3)	1	Ov/Un	2-3	4/5	N	1,2 AI
Milbank	200	CP3B5##### (x= D,P,R,S)(#=Cust. Option)		3	Un-Ped	1	7	Y	4 SS
Milbank	200	U125Y-X-HSP	(y=2-6)	1	Ov/Un	2-6	4/5	N	1,2
Milbank	200	U1980-O-HSP		1	Under	1	4/5	N	1,2
Milbank	200	U273y-XT-HSP	(y=2-6)	3	Ov/Un	2-6	7	Y	4
Milbank	200	U286y-X-HSP	(y=2-6)	1	Ov/Un	2-6	4/5	N	1,2
Milbank	200	U287y-XT-HSP	(y=2-6)	1	Ov/Un	2-6	5	Y	3,3a
Milbank	200	U3296-X-HSP		1	Ov/Un	1	5	Y	3,3a,3b
Milbank	200	U3306-X-HSP		3	Ov/Un	1	7	Y	4



Approved Metering Equipment Enclosure List

Manufacturer	Amps	Catalog Number		Phase	Service	Pos	Term	Bypass	Config
Milbank	200	U3850-XL-TG-HSP-PL		1	Ov/Un	1	4/5	N	1,2
Milbank	200	U5136-O-yyy-FMG	(yyy=41,55,75,332,552)	1	Un-Ped	1	4/5	N	1,2
Milbank	200	U5137-O-yyy-FMG	(yyy=41,55,75,332,552)	1	Un-Ped	2	4/5	N	1,2
Milbank	200	U513y-O-200P-FMG	(y=6-9)	1	Un-Ped	1-2	4/5	N	1,2
Milbank	200	U513y-O-200S-10GR-FMG	(y=6-9)	1	Un-Ped	1-2	4/5	N	1,2
Milbank	200	U513y-O-200S-FMG	(y=6-9)	1	Un-Ped	1-2	4/5	N	1,2
Milbank	200	U513y-O-FMG	(y=6-9)	1	Un-Ped	1-2	4/5	N	1,2
Milbank	200	U5842-RL-200-HSP		1	Over	1	4	N	1
Milbank	200	U6266-XTL-200-HSP		1	Ov/Un	1	4/5	N	1,2
Milbank	200	U7021-RL-TG-HSP		1	Over	1	4/5	N	1,2
Milbank	200	U7040-O-TG-HSP		1	Under	1	4	N	1,2
Milbank	200	U7040-XL-TG-5T-HSP		1	Ov/Un	1	5	N	1,2
Milbank	200	U7040-XL-TG-HSP		1	Ov/Un	1	4/5	N	1,2
Milbank	200	U7043-XL-TG		1	Ov/Un	1	4/5	N	1,2
Milbank	200	U9550-RRL-QG-HSP		1	Over	1	5	Y	3,3a,b
Milbank	200	U9551-X-QG-HSP		1	Ov/Un	1	5	Y	3,3a,b
Milbank	200	U9700-RRL-QG-HSP		3	Over	1	7	Y	4
Milbank	200	U9701-X-QG-HSP		3	Ov/Un	1	7	Y	4
Milbank	200	U9801-X-QG-HSP		1	Ov/Un	1	4	Y	1,2
Milbank	200	UAP125y-X-HSP	(y=2-6)	1	Ov/Un	2-6	4/5	Y	1,2 AI
Milbank	200	UAP1980-O-HSP		1	Under	1	4/5	N	1,2 AI
Milbank	200	UAP3296-X-HSP		1	Ov/Un	1	5	Y	3,3a,b AI
Milbank	200	UAP3306-X-HSP		3	Ov/Un	1	7	Y	4 AI
Milbank	200	UAP5024-XL		1	Ov/Un	1	4	N	1 AI
Milbank	200	UAP5024-XL-FMG		1	Ov/Un	1	4	N	1 AI
Milbank	200	UAP7021-RL-TG-HSP		1	Over	1	4/5	N	1,2 AI
Milbank	200	UAP7040-O-TG-HSP		1	Under	1	4/5	N	1,2 AI
Milbank	200	UAP7040-XL-TG-HSP		1	Ov/Un	1	4/5	N	1,2 AI
Milbank	200	UAP9550-RRL-QG-HSP		1	Over	1	5	Y	3,3a,b AI
Milbank	200	UAP9551-X-QG-HSP		1	Ov/Un	1	5	Y	3,3a,b AI
Milbank	200	UAP9700-RRL-QG-HSP		3	Over	1	7	Y	4 AI
Milbank	200	UAP9701-X-QG-HSP		3	Ov/Un	1	7	Y	4 AI
Milbank	400	U1129-O-K3L-K2L-HSP		1	Under	1	4/5	Y	3,3a
Milbank	400	U2120-O-HSP		3	Ov/Un	1	7	Y	4
Milbank	400	U2120-X-HSP		3	Ov/Un	1	7	Y	4
Milbank	400	U2124-O-HSP		1	Under	1	4	Y	3



Approved Metering Equipment Enclosure List

Manufacturer	Amps Catalog Number	Phase	Service	Pos	Term	Bypass	Config
Milbank	400 U3313-X-HSP	1	Ov/Un	1	5	Y	3,3a
Milbank	400 U3566-X-HSP	3	Ov/Un	1	7	Y	4
Milbank	400 U3949-X-HSP	1	Over	1	5	Y	3,3a
Milbank	400 U4363-X-HSP	1	Over	1	4	Y	3
Milbank	400 U5864-X-HSP	1	Ov/Un	1	5	Y	3, 3a
Milbank	400 U5890-X-2/150-HSP	1	Ov/Un	1	4	Y	3
Milbank	400 U5890-X-2/200-HSP	1	Ov/Un	1	4	Y	3
Milbank	400 U5890-X-200-150-HSP	1	Ov/Un	1	4	Y	3
Milbank	400 U5891-X-2/150-MLK-HSP	1	Ov/Un	1	4	Y	3
Milbank	400 U5891-X-2/200-MLK-HSP	1	Ov/Un	1	4	Y	3
Milbank	400 U6115-X-2/200-K7L-HSP	3	Ov/Un	1	7	Y	4
Milbank	400 U6227-X-400-K3L-HSP	1	Ov/Un	1	4	Y	3
Milbank	400 U6229-X-400-K7L-HSP	3	Ov/Un	1	5	Y	3a
Milbank	400 U6267-X-2/100-HSP	1	Ov/Un	1	4	Y	3
Milbank	400 U6267-X-2/150-HSP	1	Ov/Un	1	4	Y	3
Milbank	400 U6267-X-2/200-HSP	1	Ov/Un	1	4	Y	3
Milbank	400 U6267-X-200 -150-HSP	1	Ov/Un	1	4	Y	3
Milbank	400 U6272-X-HSP	1	Ov/Un	1	4	Y	3
Milbank	400 UAP2124-O-HSP	1	Under	1	4	Y	4 AI
Milbank	400 UAP3313-X-HSP	1	Ov/Un	1	5	Y	3,3a AI
Milbank	400 UAP3566-X-HSP	3	Ov/Un	1	7	Y	4 AI
Milbank	400 UAP3949-X-HSP	1	Over	1	5	Y	3,3a AI
Milbank	400 UAP5864-X-HSP	1	Ov/Un	1	5	Y	3, 3a AI
Milbank	400 UAP6272-X-HSP	1	Ov/Un	1	4	Y	3 AI
Milbank	600 U4667-X-8528 (Req. Ridged Lugs) FPL ONLY	3	Ov/Un	1	7	Y	5
Milbank	600 U4667-XT-9526 (Req. Ridged Lugs) FPL ONLY	3	Ov/Un	1	7	Y	5
Milbank	600 UA4667-X-8529 (Req. Ridged Lugs) FPL ONLY	3	Ov/Un	1	7	Y	5 AI
Milbank	600 UA4667-XT-9527 (Req. Ridged Lugs) FPL ONLY	3	Ov/Un	1	7	Y	5 AI
Murray	100 RJ103AXF	1	Over	1	4	N	1
Murray	150 JA0408B1150RT	1	Ov/Un	1	4	N	1
Murray	150 JA0816B1150RCT	1	Ov/Un	1	4	N	1
Murray	150 JA0816B1150RTH	1	Ov/Un	1	4/5	N	1,2
Murray	200 JA0408B1200RT	1	Ov/Un	1	4	N	1
Murray	200 JA0606L1200R or RA	1	Ov/Un	1	4/5	N	1, 1 AI
Murray	200 JA0816B1200RCT	1	Ov/Un	1	4	N	1
Murray	200 JA0816B1200RTH	1	Ov/Un	1	4/5	N	1,2



Approved Metering Equipment Enclosure List

Manufacturer	Amps Catalog Number	Phase Service	Pos	Term	Bypass	Config
Murray	200 JC0406L1200RH	1 Ov/Un	1	4/5	N	1, 2
Murray	200 RB103AR	1 Ov/Un	1	4/5	N	1,2
Murray	200 RH173CRF	1 Ov/Un	1	5	Y	3,3a
Murray	200 RH173GRF	3 Ov/Un	1	7	Y	4
Murray	200 RS103AVF	1 Under	1	4/5	N	1,2
Murray	200 RS103AXF	1 Over	1	4	N	1
Murray	400 JA0816B1350RLTM	1 Ov/Un	1	4/5	Y	1,2
Murray	400 JA0816B1400RLTM	1 Ov/Un	1	4/5	Y	1,2
Murray	400 JC0404L1400RLM	1 Ov/Un	1	4/5	Y	1,2
Siemens	125 SPxx11RJ (xx=22, 33, 44, 45, 46, 65, 66)	1 Ov/Un	2-6	4/5	N	1,2
Siemens	125 SUAT111-OGF	1 Over	1	4	N	1
Siemens	125 WMM44xxURNJ (xx=AB,BC, or CA)	3 Under	4	4/5	N	1,2
Siemens	125 WMM54xxURNJ (xx=AB,BC, or CA)	3 Under	5	4/5	N	1,2
Siemens	125 WMMx1125R (x=2-6)	1 Under	2-6	4/5	N	1,2
Siemens	125 WMMx2125RJ (x=2-6)	3 Under	2-6	5	N	2
Siemens	125 WP2211RJ	1 Mtr Ctr	2	5	N	2
Siemens	125 WP3311RJ	1 Mtr Ctr	3	5	N	2
Siemens	125 WP4X11RJ (x=4-6)	1 Mtr Ctr	4-6	5	N	2
Siemens	125 WP5411RJ	1 Mtr Ctr	4	5	N	2
Siemens	125 WP6x11RJ (x=5-6)	1 Mtr Ctr	5-6	5	N	2
Siemens	150 MC0202B1150R	1 Ov/Un	1	4/5	N	1,2
Siemens	150 MC0408B1150RT	1 Ov/Un	1	4	N	1
Siemens	150 MC0816B1150RCT	1 Ov/Un	1	4	N	1
Siemens	150 MC0816B1150RTH	1 Ov/Un	1	4/5	N	1,2
Siemens	150 MC2040B1150R	1 Ov/Un	1	4/5	N	1,2
Siemens	150 MC2040B1150RC	1 Ov/Un	1	4	N	1
Siemens	150 MC2040B1500R	1 Ov/Un	1	4/5	N	1,2
Siemens	150 MM202B1150R	1 Ov/Un	1	4/5	N	1,2
Siemens	200 MC0202B1200R	1 Ov/Un	1	4/5	N	1,2
Siemens	200 MC0408B1200RT	1 Ov/Un	1	4	N	1
Siemens	200 MC0606L1200R or RA	1 Ov/Un	1	4/5	N	1, 1 AI
Siemens	200 MC0816B1200RCT	1 Ov/Un	1	4	N	1
Siemens	200 MC0816B1200RTH	1 Ov/Un	1	4/5	N	1,2
Siemens	200 MC2040B1200R	1 Ov/Un	1	4/5	N	1,2
Siemens	200 MC2040B1200RC	1 Ov/Un	1	4	N	1
Siemens	200 MC2040S1200JLC	1 Ov/Un	1	4/5	Y	3



Approved Metering Equipment Enclosure List

Manufacturer	Amps	Catalog Number	Phase	Service	Pos	Term	Bypass	Config
Siemens	200	MM202B1200R	1	Ov/Un	1	4/5	N	1,2
Siemens	200	S40405-015F	1	Ov/Un	1	5	Y	3,3a
Siemens	200	S40407-015F	3	Ov/Un	1	7	Y	4
Siemens	200	SPxx12RJ	(xx=42, 43, 44, 65, 66)	Ov/Un	2-6	4/5	N	1,2
Siemens	200	SUAT317-OGF	1	Over	1	4	N	1
Siemens	200	SUAT417-PGF	1	Under	1	4/5	N	1,2
Siemens	200	SUAT417-XGF	1	Ov/Un	1	4/5	N	1,2
Siemens	200	UAT417-XMF	1	Ov/Un	1	5	N	2
Siemens	200	UAT417-XMF	1	Ov/Un	1	5	N	2
Siemens	200	WMMx1225R	(x=2-6)	Under	2-6	4/5	N	1,2
Siemens	200	WMMx2225RJ	(x=2-6)	Under	2-6	5	N	2
Siemens	200	WP10612RJ	1	Mtr Ctr	6	4/5	N	1,2
Siemens	200	WP4x12RJ	(x=2-4)	Mtr Ctr	2-4	4/5	N	1,2
Siemens	200	WP6x12RJ	(x=4-6)	Mtr Ctr	4-6	4/5	N	1,2
Siemens	200	WP8612RJ	1	Mtr Ctr	6	4/5	N	1,2
Siemens	200	WPL10612RJ	1	Mtr Ctr	6	4/5	Y	3,3a
Siemens	200	WPL4x12RJ	(x=2-4)	Mtr Ctr	2-4	4/5	Y	3,3a
Siemens	200	WPL6x12RJ	(x=4-6)	Mtr Ctr	4-6	4/5	Y	3,3a
Siemens	200	WPL8612RJ	1	Mtr Ctr	6	4/5	Y	3,3a
Siemens	225	WML1x225RJ	(x=1-4)	Ov/Un	1-4	4/5	Y	3,3a
Siemens	225	WMLx1225RJ	(x=2-6)	Ov/Un	2-6	4/5	Y	3,3a
Siemens	225	WMLx2225RJ	(x=1-4)	Under	1-4	7	Y	4
Siemens	225	WMLx2yz225RJ	(x=2 or 4) (yz=AB, BC or CA)	Ov/Un	2 or 4	5	Y	3,3A
Siemens	225	WMLx3225RJ	(x=1-4)	Under	1-4	7	Y	4
Siemens	250	WC2040B1TxR	(x=1-9)	Under	1	4	N	1
Siemens	250	WC2040B1TxRJ	(x=1-9)	Under	1	5	N	2
Siemens	250	WC2040B2TxRJ	(x=1-9)	Under	1	5	N	2
Siemens	250	WCL2040B1TxRJ	(x=1-9)	Under	1	4/5	N	1,2
Siemens	250	WCL2040B2TxRJ	(x=1-9)	Under	1	4/5	Y	3,3a
Siemens	250	WCL2442B3TxRJ	(x=1-9)	Under	1	7	Y	4
Siemens	400	MC0408B1400RLTM	1	Ov/Un	1	4/5	Y	3,3a
Siemens	400	MC0816B1350RLTM	1	Ov/Un	1	4/5	Y	3,3a
Siemens	400	MC0816B1400RLTM	1	Ov/Un	1	4/5	Y	3,3a
Siemens	400	MC3042B1400SDL	1	Ov/Un	1	4	N	1
Siemens	400	MM0404L1400RLM	1	Ov/Un	1	4/5	Y	3,3a
Siemens	400	WML11400RJH	1	Ov/Un	1	5	Y	3a



Approved Metering Equipment Enclosure List

Manufacturer	Amps Catalog Number		Phase	Service	Pos	Term	Bypass	Config
Siemens	400 WML12400RJH		3	Ov/Un	1	5	Y	3a
Siemens	400 WML13400RJ		3	Ov/Un	1	7	Y	4
Siemens	400 WML13400RJFS		3	Ov/Un	1	7	Y	4
Siemens	400 WML13400RJH		3	Ov/Un	1	7	Y	4
Siemens	400 WMLxy400RJ	where (x=1-2) (y=1-2)	1	Ov/Un	1	4/5	Y	3,3a
Siemens	400 WMLxy400RJFS	where (x=1-2) (y=1-2)	1	Ov/Un	1	4/5	Y	3,3a
Siemens	600 WMK13600RJ	FPL Only	1/3	Under	1	7	Y	5
Square D	100 RC3042M100PS		1	Ov/Un	1	4/5	N	1,2
Square D	100 UTZ-6R1131C-FLSQD		1	Ov/Un	6	4	N	1
Square D	100 UTZ-xR1121C-FLSQD	(x=2-5)	1	Ov/Un	2-5	4	N	1
Square D	125 EZMR11y125	(y=3-6)	1	Mtr Ctr	3-6	5	N	1,2
Square D	125 EZMR11y125CU	(y=3-6)	1	Mtr Ctr	3-6	5	N	1,2
Square D	125 EZMR11y125X	(y=3-6)	1	Mtr Ctr	3-6	5	N	1,2
Square D	125 EZMR31y125	(y=3-6)	1	Mtr Ctr	3-6	5	N	1,2
Square D	125 EZMR31y125CU	(y=3-6)	1	Mtr Ctr	3-6	5	N	1,2
Square D	125 EZMR31y125X	(y=3-6)	1	Mtr Ctr	3-6	5	N	1,2
Square D	125 MPRyy125	(yy=22,33,44,55,66)	1	Ov/Un	2-6	5	N	1,2
Square D	125 QC816F125C		1	Ov/Un	1	4/5	N	1,2
Square D	125 UATZ-RS101C-FLSQD		1	Ov/Un	1	4	N	1 AI
Square D	125 UTZ-RS101C-FLSQD		1	Ov/Un	1	4	N	1
Square D	150 QC816F150C		1	Ov/Un	1	4/5	N	1,2
Square D	150 RC3042M150PS		1	Ov/Un	1	4/5	N	1,2
Square D	150 RC816F150C		1	Ov/Un	1	4/5	N	1,2
Square D	150 RQC150SFMG		1	Ov/Un	1	4/5	N	1,2
Square D	200 EZML11y200	(y=1-4)	1	Mtr Ctr	1-4	5	Y	1,2
Square D	200 EZML31y200	(y=2-4)	1	Mtr Ctr	2-4	5	Y	3a
Square D	200 EZML33y200	(y=1-4)	3	Mtr Ctr	1	7	Y	4
Square D	200 EZMR11y200	(y=2-4)	1	Mtr Ctr	2-4	5	N	1,2
Square D	200 EZMR11y200CU	(y=2-4)	1	Mtr Ctr	2	5	N	1,2
Square D	200 EZMR11y200X	(y=2-4)	1	Mtr Ctr	2	5	N	1,2
Square D	200 MPLyy200	(yy=32,43,64)	1	Ov/Un	2-4	5	Y	3
Square D	200 MPR4y200	(y=2-3)	1	Ov/Un	2-3	5	N	1,2
Square D	200 MPR64200		1	Ov/Un	4	5	N	1,2
Square D	200 MPR8y200	(y=5-6)	1	Ov/Un	5-6	5	N	1,2
Square D	200 QC12L200C		1	Ov/Un	1	4/5	N	1,2
Square D	200 QC2442M200C		1	Ov/Un	1	4/5	Y/N	1,2



Approved Metering Equipment Enclosure List

Manufacturer	Amps	Catalog Number		Phase	Service	Pos	Term	Bypass	Config
Square D	200	QC3040M200S		1	Ov/Un	1	4/5	N	1,2
Square D	200	QC816F200C		1	Ov/Un	1	4/5	N	1,2
Square D	200	RC12L200C		1	Ov/Un	1	4/5	N	1,2
Square D	200	RC200SFMG		1	Ov/Un	1	4/5	N	1,2
Square D	200	RC2040M200C		1	Ov/Un	1	4/5	N	1,2
Square D	200	RC2M200SFMG		1	Ov/Un	1	4/5	N	1,2
Square D	200	RC3042M200PS		1	Ov/Un	1	4/5	N	1,2
Square D	200	RC816F200C		1	Ov/Un	1	4/5	N	1,2
Square D	200	RQC200SFMG		1	Ov/Un	1	4/5	N	1,2
Square D	200	UAT-H4203x-FLSQD	(x=B or T)	1	Over	1	4	Y	1 AI
Square D	200	UAT-H4213x-FLSQD	(x=C or U)	1	Ov/Un	1	4	Y	1 AI
Square D	200	UAT-H5203x-FLSQD	(x=B or T)	1	Over	1	5	Y	3,3a,b AI
Square D	200	UAT-H5213x-FLSQD	(x=C or U)	1	Ov/Un	1	5	Y	3,3a,b AI
Square D	200	UAT-H7203x-FLSQD	(x=B or T)	3	Over	1	7	Y	4 AI
Square D	200	UAT-H7213x-FLSQD	(x=C or U)	3	Ov/Un	1	7	Y	4 AI
Square D	200	UAT-RS202B-FLSQD		1	Over	1	4	N	1 AI
Square D	200	UAT-RS212C-FLSQD		1	Ov/Un	1	4	N	1 AI
Square D	200	UAT-RS213A-FLSQD		1	Under	1	4	N	1 AI
Square D	200	UAT-RS213C-FLSQD		1	Ov/Un	1	4	N	1 AI
Square D	200	UAT-RS223A-FLSQD		1	Under	1	4	N	1 AI
Square D	200	UT-4R2352U-FLSQD		1	Ov/Un	4	4	N	1
Square D	200	UT92197CC-FLSQD		1	Ov/Un	1	4	N	1
Square D	200	UT-H4203x-FLSQD	(x=B or T)	1	Over	1	4	Y	1
Square D	200	UT-H4213x-FLSQD	(x=C or U)	1	Ov/Un	1	4	Y	1
Square D	200	UT-H5203x-FLSQD	(x=B or T)	1	Over	1	5	Y	3,3a,b
Square D	200	UT-H5213x-FLSQD	(x=C or U)	1	Ov/Un	1	5	Y	3,3a,b
Square D	200	UT-H7203x-FLSQD	(x=B or T)	3	Over	1	7	Y	4
Square D	200	UT-H7213x-FLSQD	(x=C or U)	3	Ov/Un	1	7	Y	4
Square D	200	UT-RS202B-FLSQD		1	Over	1	4	N	1
Square D	200	UT-RS212C-FLSQD		1	Ov/Un	1	4	N	1
Square D	200	UT-RS213A-FLSQD		1	Under	1	4	N	1
Square D	200	UT-RS213C-FLSQD		1	Ov/Un	1	4	N	1
Square D	200	UT-RS223A-FLSQD		1	Under	1	4	N	1
Square D	200	UT-xR2332U-FLSQD	(x=2-3)	1	Ov/Un	2-3	4	N	1
Square D	200	UT-xR2392UU-FLSQD	(x=5-6)	1	Ov/Un	5-6	4	N	1
Square D	225	EZML11x225	(x=1-4)	1	Mtr Ctr	1-4	5	Y	1,2



Approved Metering Equipment Enclosure List

Manufacturer	Amps	Catalog Number		Phase	Service	Pos	Term	Bypass	Config
Square D	225	EZML31x225	(x=2-4)	1	Mtr Ctr	2-4	5	Y	3a
Square D	225	EZML33x225	(x=1-4)	3	Mtr Ctr	1	7	Y	4
Square D	225	EZMR11x200X	(x=2-4)	1	Mtr Ctr	2	5	N	1,2
Square D	225	EZMR11x225	(x=2-6)	1	Mtr Ctr	2-6	5	N	1,2
Square D	225	EZMR11x225CU	(x=2-6)	1	Mtr Ctr	2-6	5	N	1,2
Square D	225	EZMR31x225	(x=2-6)	1	Mtr Ctr	2-6	5	N	1,2
Square D	400	1008836SQD		1	Ov/Un	1	4	Y	1
Square D	400	1008837SQD		1	Ov/Un	1	4	Y	1 AI
Square D	400	EZML31y400	(y=1-2)	1	Mtr Ctr	1-2	5	Y	3a
Square D	400	EZML33y400	(y=1-2)	3	Mtr Ctr	1-2	7	Y	4
Square D	400	QU12L400xL	(x = C or S)	1	Under	1	4/5	Y	3
Square D	400	QU816D400SL		1	Under	1	4/5	Y	3
Square D	400	UAT-H4300T-FLSQD		1	Over	1	4	Y	1 AI
Square D	400	UAT-H5300T-FLSQD		1	Over	1	5	Y	3,3a,b AI
Square D	400	UAT-H5330U-FLSQD		1	Ov/Un	1	5	Y	3,3a,b AI
Square D	400	UAT-H7300T-FLSQD		3	Over	1	7	Y	4 AI
Square D	400	UAT-H7330U-FLSQD		3	Ov/Un	1	7	Y	4 AI
Square D	400	UT-H4300T-FLSQD		1	Over	1	4	Y	1
Square D	400	UT-H5300T-FLSQD		1	Over	1	5	Y	3,3a,b
Square D	400	UT-H5330U-FLSQD		1	Ov/Un	1	5	Y	3,3a,b
Square D	400	UT-H7300T-FLSQD		3	Over	1	7	Y	4
Square D	400	UT-H7330U-FLSQD		3	Ov/Un	1	7	Y	4
Talon	100	MP04061100R		1	Under	1	4	N	1
Talon	100	MP04061100R2		1	Under	2	4	N	1
Talon	100	MPS0406B1100R		1	Under	1	4	N	1
Talon	100	MPS0406B1100R2		1	Under	2	4	N	1
Talon	100	UAB111-XG		1	Ov/Un	1	4	N	1
Talon	100	UAX411-XGF	(X=2-6)	1	Ov/Un	2-6	4	N	1
Talon	125	49205-025F		1	Over	1	5	Y	3a
Talon	125	49207-025F		3	Over	1	7	Y	4
Talon	125	49305-025F		1	Over	1	5	Y	3a
Talon	125	49307-025F		3	Over	1	7	Y	4
Talon	125	MP0406B1125R		1	Under	1	4	N	1
Talon	125	MP0406B1125R2		1	Under	2	4	N	1
Talon	125	MPS0406B1125R		1	Under	1	4	N	1
Talon	125	MPS0406B1125R2		1	Under	2	4	N	1



Approved Metering Equipment Enclosure List

Manufacturer	Amps Catalog Number	Phase	Service	Pos	Term	Bypass	Config
Talon	125 TLxxRT (x=brkr/recept config.)	1	Over	1,2	4/5	N	1,2
Talon	125 TLxxxRC (x=brkr/recept config)	1	Under	1	4/5	N	1,2
Talon	125 TLxxxRM (x=brkr/recept config.)	1	Un-Ped	1,2	4/5	N	1,2
Talon	125 TLxxxRP-F (x=brkr/recept config.)	1	Un-Ped	1,2	4/5	N	1,2
Talon	125 WTG4x11RJ (X=4-6)	1	Ov/Un	5-6	5	N	2
Talon	125 WTG5411RJ	1	Ov/Un	4	5	N	2
Talon	125 WTG6x11RJ (X=5-6)	1	Ov/Un	5-6	5	N	2
Talon	125 WTGxx11RJ (X=2-4)	1	Ov/Un	2-4	5	N	2
Talon	135 UAT111-OGF	1	Ov/Un	1	4	N	1
Talon	135 UAT111-XGF	1	Ov/Un	1	4/5	N	1,2
Talon	135 UAT111-XMF	1	Ov/Un	1	5	N	2
Talon	135 UAT131-XGF	1	Ov/Un	1	4/5	N	1,2 AI
Talon	150 MP0406B1150R	1	Under	1	4	N	1
Talon	150 MP0406B1150R2	1	Under	2	4	N	1
Talon	150 MPS0406B1150R	1	Under	1	4	N	1
Talon	150 MPS0406B1150R2	1	Under	2	4	N	1
Talon	150 UAB417-150	1	Ov/Un	1	4/5	N	1,2
Talon	200 40005-01F	1	Over	1	5	Y	3,3a
Talon	200 40007-01F	3	Over	1	7	Y	4
Talon	200 40404-025F	1	Ov/Un	1	4	N	1
Talon	200 40405-015F	1	Ov/Un	1	5	Y	3,3a
Talon	200 40405-025F	1	Ov/Un	1	5	Y	3,3a
Talon	200 40405x-223F (x=2-6)	1	Ov/Un	2-6	5	Y	3a
Talon	200 40407-015F	3	Ov/Un	1	7	Y	4
Talon	200 40407-025F	3	Ov/Un	1	7	Y	4
Talon	200 40407x-223F (x=2-6)	3	Ov/Un	2-6	7	Y	4
Talon	200 41005-01F	1	Over	1	5	Y	3,3a
Talon	200 41007-01F	3	Over	1	7	Y	4 AI
Talon	200 41405-025F	1	Ov/Un	1	5	Y	3,3a AI
Talon	200 41407-025F	3	Ov/Un	1	7	Y	4 AI
Talon	200 46705-025F	1	Ov/Un	1	5	Y	3a
Talon	200 46707-025F	3	Ov/Un	1	7	Y	4
Talon	200 46805-025F	1	Ov/Un	1	5	Y	3a
Talon	200 46807-025F	3	Ov/Un	1	7	Y	4
Talon	200 LG0408B1200RT	1	Ov/Un	1	4	N	1
Talon	200 LG0606L1200R or RA	1	Ov/Un	1	4/5	N	1, 2 AI



Approved Metering Equipment Enclosure List

Manufacturer	Amps	Catalog Number	Phase	Service	Pos	Term	Bypass	Config	
Talon	200	LG0816B1200RCT	1	Ov/Un	1	4	N	1	
Talon	200	MP0406B1200R	1	Under	1	4	N	1	
Talon	200	MP0406B1200R2	1	Under	2	4	N	1	
Talon	200	MP0406L1200R	1	Under	1	4	N	1	
Talon	200	MP0406L1200R2	1	Under	2	4	N	1	
Talon	200	MPS0406B1200R	1	Under	1	4	N	1	
Talon	200	MPS0406B1200R2	1	Under	2	4	N	1	
Talon	200	UA27x6-ZGF	(x=1 or 3)	1	Ov/Un	2	4	N	1 AI
Talon	200	UA37x7-ZGF	(x=1 or 3)	1	Ov/Un	3	4	N	1 AI
Talon	200	UA47x9-ZGF	(x=1 or 3)	1	Ov/Un	4	4	N	1 AI
Talon	200	UA57x9-MGF	(x=1 or 3)	1	Ov/Un	5	4	N	1 AI
Talon	200	UA67x9-MGF	(x=1 or 3)	1	Ov/Un	6	4	N	1 AI
Talon	200	UAB417-200	1	Ov/Un	1	4/5	N	1,2	
Talon	200	UAB417-XPG	1	Ov/Un	1	4	N	1	
Talon	200	UAS877-PGF	1	Under	1	4	N	1	
Talon	200	UAT317-OGF	1	Over	1	4/5	N	1,2	
Talon	200	UAT337-OGF	1	Over	1	4/5	N	1,2 AI	
Talon	200	UAT417-PGF	1	Under	1	4/5	N	1,2	
Talon	200	UAT417-XGF	1	Ov/Un	1	4/5	N	1,2	
Talon	200	UAT417-XMF	1	Ov/Un	1	5	N	1,2 AL	
Talon	200	UAT437-PGF	1	Under	1	4/5	N	1,2 AI	
Talon	200	UAT437-XGF	1	Ov/Un	1	4/5	N	1,2 AI	
Talon	200	UAT777-XGF	1	Ov/Un	1	4	N	1	
Talon	200	UAx711-ZGF	(x=2-4)	1	Ov/Un	2-4	4	N	1
Talon	200	UAx715-MGF	(x=5-6)	1	Ov/Un	5-6	4	N	1
Talon	200	UAx71y-ZGF	(x=2-4) (y=4-5)	1	Ov/Un	2-4	4	N	1
Talon	225	WTG10612RJ	1	Ov/Un	6	5	N	2	
Talon	225	WTG4x12RJ	(X=2-4)	1	Ov/Un	2-4	5	N	2
Talon	225	WTG6x12RJ	(X=4-6)	1	Ov/Un	4-6	5	N	2
Talon	225	WTG8612RJ	1	Ov/Un	6	5	N	2	
Talon	225	WTGL10612RJ	1	Ov/Un	6	5	Y	3a	
Talon	225	WTGL4x12RJ	(x=2-4)	1	Ov/Un	2-4	5	Y	3a
Talon	225	WTGL6x12RJ	(x=4-6)	1	Ov/Un	4-6	5	Y	3a
Talon	225	WTGL8612RJ	1	Ov/Un	6	5	Y	3a	
Talon	400	40905-02FL	1	Ov/Un	1	5	Y	3a	
Talon	400	41105-02FL	1	Ov/Un	1	4/5	Y	3,3a AI	



Participants: DUKE, FPL, GULF, OGE, TECO

Approved Metering Equipment Enclosure List

Revised
2/10/17

Manufacturer	Amps Catalog Number	Phase	Service	Pos	Term	Bypass	Config
Talon	400 44707-02FL	3	Ov/Un	1	7	Y	4
Talon	400 46905-02FL	1	Ov/Un	1	5	Y	3a
Talon	400 47005-02FL	1	Ov/Un	1	5	Y	3a
Talon	400 47205-02FL	1	Ov/Un	1	5	Y	3a
Talon	400 47205-82FL	1	Ov/Un	1	5	Y	3a
Talon	400 47305-02FL	1	Ov/Un	1	5	Y	3a
Talon	400 47305-82FL	1	Ov/Un	1	5	Y	3a
Talon	400 47407-02FL	3	Under	1	7	Y	4
Talon	400 47705-02FL	1	Ov/Un	1	4/5	Y	3,3a
Talon	400 49005-02FL	1	Ov/Un	1	4/5	Y	3,3a
Talon	400 49007-02FL	3	Ov/Un	1	7	Y	4
Talon	400 49105-02FL	1	Ov/Un	1	4/5	Y	3,3a AI
Talon	400 49107-02FL	3	Ov/Un	1	7	Y	4 AI
Talon	400 UAT-131-xgf	1	Over	1	4	Y	1 AI
Talon	600 9817-9526 (Requires Ridged Lugs) FPL ONLY	1,3	Ov/Un	1	7	Y	5
Talon	600 9817-9527 (Requires Ridged Lugs) FPL ONLY	1,3	Ov/Un	1	7	Y	5 AI