



PAD	D	F	W	USE FOR TRANSFORMER SIZES
TEC NO. 2001315	45"	8"	40"	25-50 kVA
TEC NO. 2001316	52"	10"	44"	75-250 kVA

NOTES:
▶ TRANSFORMERS WITH STEEL LIDS SHALL BE BOLTED TO PAD USING 5/8" X 1-1/4" BOLTS (TEC NO. 2003167).

◀ DENOTES LATEST REVISION

NO.	CK'D	DATE	REVISION
3			
2			
1	MFK	11-4-04	REVISED NOTE, TABLE, REF. BLK., ADD 14"

<h2 style="margin: 0;">PAD DESIGN FOR</h2> <h1 style="margin: 0;">SINGLE-PHASE PAD-MOUNTED TRANSFORMERS</h1>		<p>MGR: STD'S <i>Bob Shilling</i> APPR. DATE 11-4-04 SUPERSEDES 6-11/7-20-00</p>
TAMPA ELECTRIC CO.	STANDARDS	GENERAL RULES & SPECIFICATIONS UG.
		6-11