



▲ DENOTES LATEST REVISION

GR&S 3-22

NO.	CK'D	DATE	REVISION
7	TOB	6-15-15	ADDED NOTE 14 THAT WAS REVISED ON PAGE 2
6	TOB	6-15-15	ADDED 4'-0" FROM EQUIPMENT TO FIRE HYDRANT
5	RAG	3-19-09	ADD NOTE 16, NFPA 54 & DIMENSIONS AROUND METER CAN
4	RAG	5-17-07	REV. GAS METER, ADDED NOTES 9, 13, 14 & GENERATOR

LOCATION OF OIL FILLED PAD-MOUNTED EQUIPMENT

[Signature]
 MGR: STD'S
 APPR. DATE 6-15-15
 SUPERSEDES 1-17/3-19-09

SEE NOTES ON PAGE 2 OF 2