

| REFERENCES | |
|------------|--|
| GR&S UG. | |
| SPEC. 2 | |
| SPEC. 6 | |
| STD. 7-15 | |

1" CONDUIT FOR EXTERNAL GROUNDING.
6" CLEAR OF WALLS.
SEE NOTE 10
ON PAGE 2 OF 2

APPROX.
28,596 LBS.

12 "DIA. X 4"
DEEP SUMP 2"
CLEAR OF WALLS

APPROX.
22,311 LBS.

SEE NOTE 2
ON PAGE 2 OF 2

SEE DETAIL "A"
ON PAGE 2 OF 2

SEE DETAIL "B"
ON PAGE 2 OF 2

NOTE:

1. WITH ADVANCED NOTICE, CONDUIT HOLE PATTERN CAN BE ARRANGED TO SUIT ANY APPLICATION AS NEEDED FOR THE JOB. SEE YOUR CONDUIT COORDINATOR. DETAIL A ON PAGE 2 IS AN EXAMPLE OF THE DEFAULT CONDUIT ARRANGEMENT.

◀ DENOTES LATEST REVISION

7'-0" HEAD ROOM
TEC NO. 2004691

| 4 | | | |
|-----|------|---------|------------------|
| 3 | | | |
| 2 | | | |
| 1 | JBL | 5-21-09 | ADDED NEW NOTE 1 |
| NO. | CK'D | DATE | REVISION |

MGR: STD'S *Bob Shindley*
APPR. DATE 5-21-09
SUPERSEDES 6-2/3-16-95

8' X 12' X 7'

"S" TYPE PRECAST MANHOLE